Table 4.1 SSO Inventory (Past 5 Years)
TOWN OF TEWKSBURY, MA
REVISON DATE: 7-1-2022

SSO Location[1]	Discharge Statement[2]	Date[3]	Time Start[3]	Time End[3]	Estimated Volume[4]	Description[5]	Mitigation Completed[6]	Mitigation Planned[7]
1900 Andover St.	Sewage Entered Roadway and into Catchbasins	9/7/2016	11:30 PM	7:00 AM	500 GAL	12" Force Main Burst	YES	New Force Main Installed in 2018
Darlene Circle	Sewer Manhole surged into Street	3/27/2020	12:00 PM	1:00PM	20 GAL	Sewer Backup Upstream	YES	Backup removed on same day
Heath Brook	Sewer Manhole surged into Wetland	2/14/2022	3:00	N/A	N/A	Sewer Backup Upstream	YES	Backup removed on same day
East Street	Pump Station Failure	5/19/2022	11:00 AM	12:00 PM	25 GAL	Pump Station Failure	YES	Power issue to be addresed
Grasshopper Lane	Sewer Manhole surged into Street	5/18/2022	10:00 AM	11:00 AM	100 GAL	Sewer Backup Upstream	YES	Backup removed on same day
Devonshire Road	Pump Station Failure	12/23/2021	5:30 PM	7:30 PM	50 GAL	Pump Station Failure	YES	Pump Station cleaned from blockage